



2" GALVANIZED STAND PIPE (SOLID PIECE)
THREADED BOTH ENDS – STAND PIPE
SHALL BE A MAX. OF 4" FROM LID (THREADED)
BUT SHALL NOT INTERFERE WITH
SEATING OF LID

LEGEND DESCRIPTION

- A D&L SUPPLY M-8040 CAST IRON VALVE BOX W/ LID.
(SEE STANDARD DETAIL FIGURE 5)
- B 2" GATE VALVE WITH 2" OPERATING NUT
- C CONCRETE THRUST BLOCK
- D 2" X 6" BRASS NIPPLE (MINIMUM 6" LENGTH)
- E 2" X 6" GALVANIZED NIPPLE (MINIMUM 6" LENGTH)
- F 2" PLASTIC CAP HAND TIGHT ONLY TO PROTECT THREADS

1	RSS	UPDATE	12/21/99
2	CC	UPDATE	01/2010
NO.	AUTHORIZED BY	REVISIONS	DATE



STANDARD DETAIL

FIGURE_03

WASHOUT – TYPICAL

SCALE: NONE